

ADVERTISEMENT



MKHAMBATHINI LOCAL MUNICIPALITY

REQUEST FOR QUOTATION

Advert Date 06 March 2017

The Mkhambathini Municipality invites eligible and accredited service providers to submit written quotations for supply and delivery 5 clusters.

Below is the specification for clusters required:

Air termination rod

1m galvanized 16mm mild steel
Secured firmly to top of lightning conductor

Down Conductor

6m x 80mm Nominal Bore pipe
6m X 65mm Nominal Bore pipe
6m X 50mm Nominal Bore Pipe
6m X 40mm Nominal Bore Pipe

Down conductor shall be securely connected overlap and bolt arrangement and must be completed using High Tensile Galvanised Bolts and Reducing sockets.

Earth Termination Rod

2 X 16mm x 1.2m copper coated earth rod
Connected firmly to the down conductor by means of self threading bolt and Brass earth clamps
10mm earth wire to be used for connection between down conductor and earth termination rods.

Installation

The lightning conductor shall be installed in a hole that is no less than 1.2m deep Holes are to be dug using mechanical means either by means of earth Auger machine or earth coring Machine
Lightning conductors shall be stamped firm and held in place with 25MPA concrete. A concrete plinth measuring 1m x 1m x 300mm shall be cast around the base of the lightning conductor to ensure stability.

Quotations with the valid tax clearance certificate i.e CK1, all MBD forms to be filled BBBEE Certificate and central supplier database registration confirmation sealed in an envelope marked with Quotation for the Plastic chairs, must be deposited during the office hours, 8H00 to 16H15, Monday to Friday in the Supply Chain Management

Unit of Mkhambathini Local Municipality, 18 Old Main Road, Camperdown, 3720, on or before **14 March 2017**.

For more information please contact SCM officer on (031) 785 9338

Late and Faxed quotations will not be accepted.

T.C Ndlela
MUNICIPAL MANAGER